



Environmental Hazards Services, L.L.C.  
7469 Whitepine Rd  
Richmond, VA 23237  
Telephone: 800.347.4010

## Lead in Drinking Water Analysis Report

**Client:** Stohl Environmental  
3860 California Road  
Orchard Park, NY 14127

**Report Number:** 20-12-01892

**Received Date:** 12/14/2020  
**Reported Date:** 12/28/2020  
**Sampled By:** Sean Hanley  
**Tech Certification #:**

**Project/Test Address:** 2020L-105.2; Holland Middle School; 11720 Partridge Rd; Holland, NY 14080

**Client Number:**  
33-5980

**Fax Number:**  
716-312-8092

# Laboratory Results

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-12-01892-001	105.2-5	12/10/2020	CONCESSIONS BOYS BATHROOM	<1.00	12/24/2020	
20-12-01892-002	105.2-6	12/10/2020	CONCESSION STAND LEFT	3.18	12/24/2020	
20-12-01892-003	105.2-22	12/10/2020	KITCHEN DISH WASH	18.6	12/24/2020	
20-12-01892-004	105.2-33	12/10/2020	GIRLS LAV ACROSS FROM OFFICE	11.3	12/24/2020	
20-12-01892-005	105.2-37	12/10/2020	NURSES OFFICE	8.16	12/24/2020	
20-12-01892-006	105.2-62	12/10/2020	ROOM 204	5.44	12/24/2020	

# Environmental Hazards Services, L.L.C

**Client Number:** 33-5980

**Report Number:** 20-12-01892

**Project/Test Address:** 2020L-105.2; Holland Middle School; 11720 Partridge Rd; Holland, NY 14080

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
-------------------	------------------	-----------------	---------------------	--------------------------	---------------	--------------

**Method:** SM 3113B-2010

**Analyst:** Jennalee Hertzler

**Accreditation #:** NY 11714

Reviewed By Authorized Signatory:

*Melissa Kanode*

*Missy Kanode*

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND                      ug/L= micrograms per liter                      ppb = parts per billion

