



Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: Stohl Environmental
3860 California Road
Orchard Park, NY 14127

Report Number: 20-12-01900

Received Date: 12/14/2020
Reported Date: 12/28/2020
Sampled By: Sean Hanley
Tech Certification #:

Project/Test Address: 2020L-105.3; Holland Elementary School; 103 Canada St; Holland, NY 14080

Client Number:
33-5980

Fax Number:
716-312-8092

Laboratory Results

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-12-01900-001	105.3-7	12/10/2020	ROOM 2 CLASSROOM	1.98	12/24/2020	
20-12-01900-002	105.3-10	12/10/2020	ROOM 3 CLASSROOM	16.3	12/24/2020	
20-12-01900-003	105.3-32	12/10/2020	ROOM 11 CLASSROOM	2.41	12/24/2020	
20-12-01900-004	105.3-34	12/10/2020	ROOM 12 BATHROOM	1.39	12/24/2020	
20-12-01900-005	105.3-39	12/10/2020	ROOM 13 CLASSROOM	1.78	12/24/2020	
20-12-01900-006	105.3-52	12/10/2020	ROOM 18 CLASSROOM	7.91	12/24/2020	
20-12-01900-007	105.3-67	12/10/2020	ROOM 21	6.33	12/24/2020	
20-12-01900-008	105.3-69	12/10/2020	ROOM 22	5.16	12/24/2020	
20-12-01900-009	105.3-71	12/10/2020	ROOM 24	13.9	12/24/2020	
20-12-01900-010	105.3-98	12/10/2020	BOYS LOCKER ROOM	<1.00	12/24/2020	
20-12-01900-011	105.3-101	12/10/2020	MUSIC ROOM 56	7.56	12/24/2020	
20-12-01900-012	105.3-105	12/10/2020	ROOM 74 BATHROOM	9.05	12/24/2020	
20-12-01900-013	105.3-106	12/10/2020	ROOM 74 CLASSROOM	9.56	12/24/2020	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 20-12-01900

Project/Test Address: 2020L-105.3; Holland Elementary School; 103 Canada St; Holland, NY 14080

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-12-01900-014	105.3-112	12/10/2020	LAUNDRY ROOM	3.41	12/24/2020	
20-12-01900-015	105.3-115	12/10/2020	KITCHEN SINK NEAR CORNER	58.0	12/24/2020	

Method: SM 3113B-2010

Analyst: Jennalee Hertzler

Accreditation #: NY 11714

Reviewed By Authorized Signatory:

Melissa Kanode

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion

