



Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: Stohl Environmental
3860 California Road
Orchard Park, NY 14127

Report Number: 20-12-01895

Received Date: 12/14/2020
Reported Date: 12/28/2020
Sampled By: Sean Hanley
Tech Certification #:

Project/Test Address: 2020L-105.1; Holland High School; 103 Canada St; Holland, NY 14080

Client Number:
33-5980

Fax Number:
716-312-8092

Laboratory Results

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-12-01895-001	105.1-4	12/10/2020	NURSES OFFICE	6.54	12/24/2020	
20-12-01895-002	105.1-23	12/10/2020	LADIES LAV	4.17	12/24/2020	
20-12-01895-003	105.1-44	12/10/2020	ROOM 200	6.49	12/24/2020	
20-12-01895-004	105.1-71	12/10/2020	ROOM 111	3.95	12/24/2020	

Method: SM 3113B-2010
Analyst: Jennalee Hertzler
Accreditation #: NY 11714

Reviewed By Authorized Signatory:

Melissa Kanode

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion

