



Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: Stohl Environmental
3860 California Road
Orchard Park, NY 14127

Report Number: 22-04-04340

Received Date: 04/20/2022

Reported Date: 04/27/2022

Sampled By: Andrew Theal

Tech Certification #:

Project/Test Address: 2020L-105.3; Holland Elementary; 173 Canada Street; Holland, NY

Client Number:
33-5980

Laboratory Results

Fax Number:
716-312-8092

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
22-04-04340-001	105.3-37A	04/14/2022	DRINKING FOUNTAIN	<1.00	04/27/2022	
22-04-04340-002	105.3-37B	04/14/2022	DRINKING FOUNTAIN	<1.00	04/22/2022	
22-04-04340-003	105.3-59	04/14/2022	DRINKING FOUNTAIN	<1.00	04/22/2022	
22-04-04340-004	105.3-88A	04/14/2022	DRINKING FOUNTAIN	<1.00	04/22/2022	
22-04-04340-005	105.3-88B	04/14/2022	DRINKING FOUNTAIN	<1.00	04/22/2022	
22-04-04340-006	105.3-95	04/14/2022	DRINKING FOUNTAIN	<1.00	04/22/2022	
22-04-04340-007	105.3-102	04/14/2022	DRINKING FOUNTAIN	<1.00	04/22/2022	
22-04-04340-008	105.3-111	04/14/2022	DRINKING FOUNTAIN	<1.00	04/22/2022	
22-04-04340-009	105.3-115	04/14/2022	DRINKING FOUNTAIN	2.62	04/22/2022	
22-04-04340-010	105.3-10	04/14/2022	DRINKING FOUNTAIN	4.58	04/22/2022	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 22-04-04340

Project/Test Address: 2020L-105.3; Holland Elementary; 173 Canada Street;
Holland, NY

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
----------------------	---------------------	--------------------	---------------------	-----------------------------	------------------	-----------------

Method: EPA 200.8

Analyst: Allison Rodriguez

Accreditation #: NY 11714

Reviewed By Authorized Signatory:

Melissa Kanode

Melissa Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLNENVIRONMENTAL.COM

Submitted to: (Lab Name) _____

STOHL Job # 2020L-105.3

Client: Holland CSD

Contact: Jay Peplin

Building: Holland Elementary

Location: 173 Canada Street Holland NY

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9

X

Turnaround

5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
105.3-37A	Drinking Fountain	DF				
105.3-37B	Drinking Fountain	DFB				
105.3-59	Drinking Fountain	DF				
105.3-88A	Drinking Fountain	DF				
105.3-88B	Drinking Fountain	DFB				
105.3-95	Drinking Fountain	DF				
105.3-102	Drinking Fountain	DF				
*3 extra samples received *4/20/22						
*105.3-111						
*105.3-115						
*105.3-10						

22-04-04340



Due Date:
04/27/2022
(Wednesday)
AE

[Handwritten signature]

Notes:

Please e-mail lab results to labs@stohlenv.com

☒ If checked, also e-mail results to:

ehenderson@stohlenv.com

Sampled By: Andrew Theal

Print Name

Stohl Env: Andrew Theal

Date: 4/14/2022

Relinquished By: *[Signature]*

Print Name

Stohl Env: Eric Henderson Jr.

Date: 4/15/2022

Received (Name / Lab):

Amy Vejnar

Date: 4/20/22

Time: 1:21 PM

Sample Login (Name / Lab):

Aasa Swart

Date: 4/20/22

Time: 3:12 PM

Analysis (Name / Lab):

Alison Rodz

Date: 4/27/22

Time: 2:41 AM

QA/QC Review (Name / Lab):

[Signature]

Date: 4/26/22

Time: 5 PM

Archived / Released:

QA/QC InterLAB Use:

Date:

Time:

