



Environmental Hazards Services, L.L.C.  
7469 Whitepine Rd  
Richmond, VA 23237  
Telephone: 800.347.4010

## Lead in Drinking Water Analysis Report

**Client:** Stohl Environmental  
3860 California Road  
Orchard Park, NY 14127

**Report Number:** 22-04-04346

**Received Date:** 04/20/2022

**Reported Date:** 05/02/2022

**Sampled By:** Andrew Theal

**Tech Certification #:**

**Project/Test Address:** 2020L-105.1; Holland High School; 103 Canada St; Holland, NY

**Client Number:**

33-5980

# Laboratory Results

**Fax Number:**

716-312-8092

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
22-04-04346-001	105.1-5	04/14/2022	CARDIO BOTTLE	<1.00	04/27/2022	
22-04-04346-002	105.1-10	04/14/2022	CO 419B	<1.00	04/27/2022	
22-04-04346-003	105.1-20	04/14/2022	GYM ENTRANCE BOTTLE	<1.00	04/27/2022	
22-04-04346-004	105.1-26	04/14/2022	CAFE BOTTLE	<1.00	04/27/2022	
22-04-04346-005	105.1-35	04/14/2022	GLR	<1.00	04/27/2022	
22-04-04346-006	105.1-36	04/14/2022	WEIGHT ROOM	<1.00	04/27/2022	
22-04-04346-007	105.1-38	04/14/2022	BLR	<1.00	04/27/2022	
22-04-04346-008	105.1-51	04/14/2022	CO 208	<1.00	04/27/2022	
22-04-04346-009	105.1-73	04/14/2022	CP PROJ RM	<1.00	04/27/2022	

# Environmental Hazards Services, L.L.C

**Client Number:** 33-5980

**Report Number:** 22-04-04346

**Project/Test Address:** 2020L-105.1; Holland High School; 103 Canada St;  
Holland, NY

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
----------------------	---------------------	--------------------	---------------------	-----------------------------	------------------	-----------------

**Method:** EPA 200.8

**Analyst:** Allison Rodriguez

**Accreditation #:** NY 11714

Reviewed By Authorized Signatory:

*Melissa Kanode*

Melissa Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND                      ug/L= micrograms per liter                      ppb = parts per billion



Submitted to: (Lab Name) EHS

STOHL Job # 2020L-105.1

Client: Holland CSD Contact: Scott Christ

Building: Holland High School Location: 103 Canada St., Holland NY

**LEAD**

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9

X

## Turnaround

20 Days

22-04-04346

Due Date:  
05/18/2022  
(Wednesday)  
AE

Notes:

Please e-mail lab results to [labs@stohlenv.com](mailto:labs@stohlenv.com)

☐ If checked, also e-mail results to: \_\_\_\_\_

Sampled By: Andrew Theal      Print Name      Stohl Env: Andrew Theal      Date: 4/14/2022

Relinquished By: Eric Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 4/15/2022

Received (Name / Lab): ANN V. P. NAY Date: 4/20/22 Time: 1:27 PM

Sample Login (Name / Lab): Angela Hunt Date: 01/20/20 Time: 3:13 PM

Analysis (Name / Lab): Allen Park Date: 11/07/22 Time: 3:30

QA/QC Review (Name / Lab): Muhhl Date: 4/29/12 Time: 1:00pm

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

