



Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: Stohl Environmental
3860 California Road
Orchard Park, NY 14127

Report Number: 22-04-04332

Received Date: 04/20/2022

Reported Date: 05/02/2022

Sampled By: Andrew Theal

Tech Certification #:

Project/Test Address: 2020L-105.2; Holland Middle School; 11720 Partridge Rd; Holland, NY

Client Number:

33-5980

Laboratory Results

Fax Number:

716-312-8092

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
22-04-04332-001	105.2-8	04/14/2022	GIRLS LOCKER	<1.00	04/27/2022	
22-04-04332-002	105.2-11	04/14/2022	POOL	1.16	04/27/2022	
22-04-04332-003	105.2-13	04/14/2022	BOYS LOCKER	<1.00	04/27/2022	
22-04-04332-004	105.2-27	04/14/2022	LOBBY FOUNTAIN	<1.00	04/27/2022	
22-04-04332-005	105.2-87	04/14/2022	ACROSS FROM RM 109	<1.00	04/27/2022	
22-04-04332-006	105.2-88A	04/14/2022	2ND FLOOR HALLWAY	<1.00	04/27/2022	
22-04-04332-007	105.2-88B	04/14/2022	2ND FLOOR HALLWAY	<1.00	04/27/2022	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 22-04-04332

Project/Test Address: 2020L-105.2; Holland Middle School; 11720 Partridge Rd; Holland, NY

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
-------------------	------------------	-----------------	---------------------	--------------------------	---------------	--------------

Method: EPA 200.8

Analyst: Allison Rodriguez

Accreditation #: NY 11714

Reviewed By Authorized Signatory: Melissa Kanode

Melissa Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion

